



**NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl



**CERTIFICATE OF CONSTANCY OF PERFORMANCE
1488-CPR-0651/W**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Powered smoke and heat exhaust roof ventilator
type RFHT F400**

classified in accordance with EN 13501-4:2016

F₄₀₀120

essential characteristics, general identification and intended use are described in the Annex No. Z-1488-CPR-0651/W which is an integral part of this certificate

placed on the market under the name or trade mark of:

**VENTURE INDUSTRIES Sp. z o.o.
ul. Mokra 27
05-092 Łomianki – Kielpin
Poland**

and produced in the manufacturing plants:

**VENTURE INDUSTRIES Sp. z o.o.
ul. Mokra 27
05-092 Łomianki
Poland
and
VENTURE INDUSTRIES Sp. z o.o. Oddział Grudziądz
ul. Lotnicza 21A
86-300 Grudziądz
Poland**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 07.02.2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



Warsaw, 07.02.2018

DIRECTOR
of Instytut Techniki Budowlanej

Robert Geryto, Ph. D.



**NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl



ANNEX No. Z-1488-CPR-0651/W page 1/1 - which is integral part of the certificate no. 1488-CPR-0651/W

Powered smoke and heat exhaust exhaust roof ventilator type RFHT F400

List of essential characteristics of construction product according to EN 12101-3:2015

No.	Essential characteristics of the product	Harmonized technical specification EN 12101-3:2015	Regulatory classes	Essential characteristics
1.	Operational reliability: - application categories - motor rating	4.2.2 4.2.3	According to Table 1 of EN 12101-3:2015 and EN 60085	- uninsulated - adapted to work outside the smoke tank - adapted to work in a vertical position, - dual-purpose - cooled with air supplied from the outside - class of motor insulation F
2.	Resistance to fire	4.4	According to EN 13501-4	F ₄₀₀ 120

Declared intended use of product: smoke and heat control ventilation systems


General identification:

Variants	RFHT/2-355T F400	RFHT/4-450T F400	RFHT/4-630T F400	RFHT/6-900T F400						
	RFHT/4-355T F400	RFHT/6-450T F400	RFHT/6-630T F400	RFHT/6/12-900T F400						
	RFHT/2/4-355T F400	RFHT/4/6-450T F400	RFHT/4/6-630T F400	RFHT/6-1000T F400						
	RFHT/6-355T F400	RFHT/4-500T F400	RFHT/4-710T F400	RFHT/6/12-1000T F400						
	RFHT/4/6-355T F400	RFHT/6-500T F400	RFHT/6-710T F400	-						
	RFHT/4-400T F400	RFHT/4/6-500T F400	RFHT/4/6-710T F400	-						
	RFHT/6-400T F400	RFHT/4-560T F400	RFHT/4-800T F400	-						
	RFHT/4/6-400T F400	RFHT/6-560T F400	RFHT/6-800T F400	-						
Dimensional range [mm]	Ø 355	Ø 400	Ø 450	Ø 500	Ø 560	Ø 630	Ø 710	Ø 800	Ø 900	Ø 1000

Detailed identification, scope and conditions of use are included in the classification report no. 01351/17/Z00NZZP dated 25.09.2017

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



Warsaw, 07.02.2018

DIRECTOR
of Instytut Techniki Budowlanej

Robert Geryło, Ph. D.



**INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSAW, POLAND
tel.: + 48 (22) 57 96 167, + 48 (22) 57 96 168, fax: + 48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl

CERTIFICATION MARK

The company

VENTURE INDUSTRIES Sp. z o.o.
ul. Mokra 27
05-092 Łomianki - Kiełpin

being the manufacturer of the product

**Powered smoke and heat exhaust roof ventilator
type RFHT F400**

is authorized to use
the ITB certification mark „WYRÓB BUDOWLANY”
during the period of validity of the certificate no. 1488-CPR-0651/W



1488-CPR-0651/W

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



Warsaw, 07.02.2018

DIRECTOR
of Instytut Techniki Budowlanej

Robert Geryło, Ph. D.